



Fire access roads shall be extended to allow access to all buildings. No portion of any building shall exceed 150 feet (by the lay of a hose line), measured from the access road.