

**May 26, 2020**

**Attention: Mr. Mike Wnek  
Wnek Engineering  
P.O. Box 776  
Tracyton, WA 98393**

**GEOLOGICAL ASSESSMENT, ADDENDUM #1  
SINGLE FAMILY RESIDENCE SITE  
1665 NW SHERWOOD ST. / 1719 STANTON WAY NW  
KITSAP COUNTY PARCEL NUMBER 4973-000-008-0106  
BREMERTON WASHINGTON**

**Dear Mr. Wnek:**

Resolve Environmental and Geotechnical, Incorporated (Resolve) is presenting this addendum to our Geotechnical Engineering Investigation Report, dated January 9, 2020. The object of the addendum is to provide an agreement with the proposed drainage plan at the new construction site in regard to geological issues. The drainage plan prepared by Wnek Engineering, and dated 05/22/2020, has been reviewed for this addendum.

The drainage for the building is as follows:

- The north downspout drains to the gravel driveway and eventually disperse westerly into the lawn
- The south roof has no downspout, it drains to a rock bed which will disperse to the west.
- The gravel drive continues to drain as it always has: dispersing in the lawn to the west.

It is Resolve's opinion that the drainage plan will not impact local geologic conditions, as it is adequately dispersed before reaching the top-of-slope.

Resolve appreciates the opportunity to provide these services, and hopes the information presented in this addendum provides for your needs and requirements. Please feel free to call with any comments or questions regarding this letter report. Our telephone number is (360) 865-1843.

Sincerely,  
Resolve Environmental & Geotechnical, Inc.



Ronald P. Nance, P.G.  
Senior Geologist and Environmental Professional  
WA License No. 2533