

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

2322 Basic
Establish a Basic Permit
Port Orchard, WA 98367

Contact Information

Disney and Associates, Inc.
5706 Bethel Road SE Suite 100
Port Orchard, WA 98367

Heating System Type:

☐ All Other Systems ☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

[Instructions](#)

Port Orchard

Design Temperature Difference (ΔT)
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

41

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

2,322

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.0

Conditioned Volume
20,898

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
0.280 X 504 = 141.06

U-Factor X Area = UA
0.50 X 16 = 8.00

Skylights

[Instructions](#)

Insulation

Attic

[Instructions](#)

R-49

U-Factor X Area = UA
0.026 X 2,178 = 56.63

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA
0.027 X 2,178 = 58.81

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
0.056 X 3,748 = 209.89

Floors

[Instructions](#)

R-30

U-Factor X Area = UA
0.029 X 2,322 = 67.34

Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA
0.042 X 1,137 = 47.75

Slab Below Grade (see Figure 1)

[Instructions](#)

R-10 Fully insulated

F-Factor X Length = UA
0.303 X 144 = 43.63

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
--- X --- = ---

Location of Ducts


[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient
1.10

CHANGES
MUST Be Approved Prior
To Performing Work

Figure 1.



Sum of UA 633.11
Envelope Heat Load 25,958 Btu / Hour
Sum of UA X ΔT
Air Leakage Heat Load 9,254 Btu / Hour
Volume X $0.6 \times \Delta T \times .018$
Building Design Heat Load 35,211 Btu / Hour
Air Leakage + Envelope Heat Loss
Building and Duct Heat Load 38,732 Btu / Hour
Ducts in unconditioned space: Sum of Building Heat Loss X 1.10
Ducts in conditioned space: Sum of Building Heat Loss X 1
Maximum Heat Equipment Output 48,415 Btu / Hour
Building and Duct Heat Loss X 1.40 for Forced Air Furnace
Building and Duct Heat Loss X 1.25 for Heat Pump

Established Basic Permit #
19-05700

Permit Number: 20-00762