



civil & structural
engineering & planning




STRUCTURAL ANALYSIS REPORT

SE06033A – Burke

Water Tank Site

6563 Sunset Ave NE
Bremerton, WA 98310



250 4th Ave S Ste 200
Edmonds, WA 98020
Phone: (425) 778-8500
Fax: (425) 778-5536

CG Project No.: 20070.667

Permit Number: 20-04364

TABLE OF CONTENTS

SECTION TITLE / DESCRIPTION	PAGE NO.
STRUCTURAL ANALYSIS NARRATIVE	1-3
SITE PLAN	4
SITE DATA	5-9
LATERAL LOAD CALCULATIONS	10-11
APPURTENANCE & MAIN STRUCTURE ANALYSIS	12-22
EQUIPMENT CABINET ANCHORAGE	23-24
ARCHITECTURAL DRAWINGS (EXCERPT)	A1-A7

INTRODUCTION

CG Engineering was retained by B.J. Thomas, PE (Client) to provide structural analysis of the existing structure for the site modifications proposed by T-Mobile.

The structural analysis completed by CG Engineering was inclusive of the structural elements that were affected by the addition of equipment and antennas associated with the proposed T-Mobile site modifications. Where applicable, this includes the antenna and equipment support structure and affected portions of the existing main structure.

SITE DESCRIPTION

The appurtenances are mounted to an existing steel antenna braced frame located on the top of a cylindrical, 90' tall steel water tank. The existing steel braced frame is anchored to the roof with (6) 1/2" threaded rods, (2) per sector, and (3) L3x3x1/4 steel angle kicker braces, (1) per sector.

The Client provided us with structural calculations for a previous antenna upgrade dated 07/18/19. CG Engineering also had access to structural calculations for previous antenna upgrades by CG Engineering dated 06/23/2015 and by Cornerstone Engineering dated 10/17/12. Photos of the site and architectural plans were also provided for the proposed revisions. All geometry, member sizes, and material strengths used in our analysis were based on this information. If anything differs from the information contained in these documents, CG Engineering should be notified to revise our analysis.

APPURTENANCE CONFIGURATION

The structure was analyzed using the appurtenance configuration specified in the following table. All loading was provided to us from the Client. This table includes all known existing and future antennas for this site.

Sector	Existing Appurtenance Configuration	Proposed Appurtenance Configuration (Bold=New)	Mount Type
A	(2) Commscope Panel Antennas Model No. TMBXX-6516-R2M (1) Commscope Panel Antenna Model No. FFHH-65C-R3 (1) AHLOA (1) COVP (1) AHFIB (1) FXFB (2) DUAL PCS/AWS TMA	(1) Commscope Panel Antennas Model No. TMBXX-6516-R2M (1) Commscope Panel Antenna Model No. FFHH-65C-R3 (1) Nokia Radio Antenna Model No. AEHC (1) AHLOA (1) COVP (1) AHFIG (1) FXFB (1) FRIA	Mount appurtenances to existing 2-1/2" pipe mounts
B	(2) Commscope Panel Antennas Model No. TMBXX-6516-R2M (1) Commscope Panel Antenna Model No. FFHH-65C-R3 (1) AHLOA (1) COVP (1) AHFIB (1) FXFB (2) DUAL PCS/AWS TMA	(1) Commscope Panel Antennas Model No. TMBXX-6516-R2M (1) Commscope Panel Antenna Model No. FFHH-65C-R3 (1) Nokia Radio Antenna Model No. AEHC (1) AHLOA (1) AHFIG (1) FXFB (1) FRIA (2) HCS 2.0 Pendants	Mount appurtenances to existing 2-1/2" pipe mounts

Table continued on following page...



250 4th Avenue South, Suite 200
Edmonds, WA 98020
ph. 425.778.8500 | f. 425.778.5536
www.cgengineering.com

...table continued from previous page.

G	(2) Commscope Panel Antennas Model No. TMBXX-6516-R2M (1) Commscope Panel Antenna Model No. FFHH-65C-R3 (1) AHLOA (1) COVP (1) AHFIB (1) FXFB (2) DUAL PCS/AWS TMA	(1) Commscope Panel Antennas Model No. TMBXX-6516-R2M (1) Commscope Panel Antenna Model No. FFHH-65C-R3 (1) Nokia Radio Antenna Model No. AEHC (1) AHLOA (1) AHFIG (1) FXFB (1) FRIA	Mount appurtenances to existing 2-1/2" pipe mounts

The coax cables that serve the antennas weigh less than 5 lb/ft and are therefore exempt from the requirements of Chapter 13 of ASCE 7.

LEASE AREA EQUIPMENT

All loading for the equipment was provided to us from the client. The client is proposing the following modifications at the equipment cabinets: remove (1) Purcell cabinet, add **(1) HPL3 600A Support Cabinet**, and add **(1) LB3 Battery Cabinet**.

ANALYSIS CRITERIA

The parameters in the following table were used in our analysis of the structure based on its location.

City of Seattle, WA				
Wind Criteria			Seismic Criteria	
Basic Wind Speed w/o Ice (3-s Gust):	110 mph	Risk Category:	IV	Sds: 0.975
Exposure:	B	Kzt (ASCE 7-10):	1.30	Sd1: 0.579
Notes: 1. Refer to the attached topographic maps used to determine the topographic factor. 2. Parameters based on the 2012 International Building Code (IBC) and referenced standards.				

APPURTENANCE MOUNT/MAIN STRUCTURE ANALYSIS RESULTS

Individual appurtenance mounts have been determined to be sufficient to support the proposed loads. Additionally, the existing structure has been determined to be sufficient to support the proposed appurtenance configuration.

CONCLUSIONS/RECOMMENDATIONS

We have determined that no upgrades to the existing structure are required for the proposed T-Mobile installation as described above in the appurtenance configuration tables.

- **Appurtenance Anchorage:**
The appurtenances shall attach to the existing 2-1/2" standard pipe mounts on the existing steel braced frame. Attach the appurtenances to the pipe mounts with the mounting hardware provided by the manufacturer and in accordance with their installation instructions.
- **Equipment Anchorage:**
The new equipment cabinet shall mount to the existing concrete slab with (4) 3/8" ϕ HILTI Kwik Bolt TZ wedge anchors with a 2" embedment into the concrete, (1) each corner.

CONDITIONS OF ANALYSIS



This structural analysis is based on the documentation that was available to us. CG Engineering did not perform an observation of this site to verify the accuracy of the provided structure and appurtenance data, and we should be contacted immediately if there are any discrepancies with the information stated within this report.

Our analysis is based on the assumption that the structure has been properly installed and is maintained to the minimum standards required by code. We assume the structure has no known deterioration or damage that would adversely affect its capacity.

REFERENCE DOCUMENTS

The following documents were provided to us by the Client for our analysis:

1. "STRUCTURAL ANALYSIS REPORT SE06033A Burke", by CG Engineering, dated 07/18/2019
2. "SE06033A Burke Structural Calculations" by Cornerstone Engineering, dated 10/17/2012
3. "Structural Calculations for Burke Water Tank SE6033A" by EISI Ltd., dated 10/23/1998




250 4th Ave. South
Suite 200
Edmonds, WA 98020

Description	By	Date
SITE PLAN	CGP	09/15/20
	Checked	Date
	Scale	Sheet No.
Project	Job No.	4
	20070.667	

Permit Number: 20-04364

Search Information

Coordinates: 47.622706, -122.608525
Elevation: 402 ft
Timestamp: 2020-09-14T21:45:19.716Z
Hazard Type: Seismic
Reference Document: ASCE7-10
Risk Category: IV
Site Class: D



Basic Parameters

Name	Value	Description
S _S	1.465	MCE _R ground motion (period=0.2s)
S ₁	0.58	MCE _R ground motion (period=1.0s)
S _{MS}	1.465	Site-modified spectral acceleration value
S _{M1}	0.87	Site-modified spectral acceleration value
S _{DS}	0.977	Numeric seismic design value at 0.2s SA
S _{D1}	0.58	Numeric seismic design value at 1.0s SA

Additional Information



Name	Value	Description
SDC	D	Seismic design category
F _a	1	Site amplification factor at 0.2s
F _v	1.5	Site amplification factor at 1.0s
CR _S	0.961	Coefficient of risk (0.2s)
CR ₁	0.932	Coefficient of risk (1.0s)
PGA	0.608	MCE _G peak ground acceleration
F _{PGA}	1	Site amplification factor at PGA
PGA _M	0.608	Site modified peak ground acceleration
T _L	6	Long-period transition period (s)
SsRT	1.465	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.524	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	2.961	Factored deterministic acceleration value (0.2s)
S1RT	0.58	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.622	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	1.238	Factored deterministic acceleration value (1.0s)
PGAd	1.138	Factored deterministic acceleration value (PGA)

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adaption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.

DELORME



Data use subject to license.



© DeLorme. Topo North America™ 10.

www.delorme.com

Permit Number: 20-04364

Scale 1 : 43,750







Data use subject to license.



© DeLorme, Topo North America™ 10.

www.delorme.com

Permit Number: 20-04364



7




Lin Dist: 4.0 mi	Terr Dist: 4.0 mi	Elev Gain: -293.5 ft	Avg Grade: 3
Climb Elev: 245.0 ft	Desc Elev: 538.5 ft	Max. Elev: 411.3 ft	Min. Elev: -0.6 ft
Climb Dist: 1.2 mi	Desc Dist: 2.1 mi		

Data use subject to license.



© DeLorme. Topo North America™ 10.

www.delorme.com

Permit Number: 20-04364



6




Data use subject to license.

© DeLorme. Topo North America™ 10.

www.delorme.com

Permit Number: 20-04364



Seismic Load Calculation for Components and System

(Reference: IBC 2015 Section 1613 & ASCE 7-10 Section 13.3)

Seismic Force:

0.2s Spectral Response Acceleration, Site Class B, S_s	=	1.465	(ASCE 7, Figure 22-1 thru 22-6)
1.0s Spectral Response Acceleration, Site Class B, S_1	=	0.580	(ASCE 7, Figure 22-1 thru 22-6)
Site Class	=	D	(ASCE 7, Section 11.4.2)
Seismic Design Category	=	D	(ASCE 7, Tables 11.6-1 & 11.6-2)
Site Coefficient per S_s & Site Class, F_a	=	1.00	(ASCE 7, Table 11.4-1)
Site Coefficient per S_1 & Site Class, F_v	=	1.50	(ASCE 7, Table 11.4-2)
$S_{MS} = F_a S_s$	=	1.465	(ASCE 7, Section 11.4.3)
$S_{M1} = F_v S_1$	=	0.870	(ASCE 7, Section 11.4.3)
$S_{D5} = 2/3 S_{MS}$	=	0.977	(ASCE 7, Section 11.4.4)
$S_{D1} = 2/3 S_{M1}$	=	0.580	(ASCE 7, Section 11.4.4)

(Per ASCE 7-10, 13.3)

Component Amplification Factor, a_p	=	1.0	(ASCE 7, Table 13.6-1)
Component Response Modification Factor, R_p	=	2.5	(ASCE 7, Table 13.6-1)
Component Importance Factor, I_p	=	1.0	(ASCE 7, Table 1.5-2)
Component Operating Weight, W_p	=	W_p	(lb)
Height in structure at lowest point of attachment of component, z_1	=	87.25	(ft)
Height in structure at highest point of attachment of component, z_2	=	95.25	(ft)
Average Roof Height of Structure, h	=	88	(ft)

$$\text{Seismic design force, } F_p = \frac{0.4a_p S_{D5} W_p}{R_p / I_p} (1 + 2z/h) \quad (\text{Eq. 13.3-1})$$

$$\text{Max. seismic design force, } F_{p\max} = 1.6 S_{D5} I_p W_p \quad (\text{Eq. 13.3-2})$$


$$\text{Min. seismic design force, } F_{p\min} = 0.3 S_{D5} I_p W_p \quad (\text{Eq. 13.3-3})$$

$$\begin{aligned} \text{Seismic design force at lowest point, } F_{p1} &= 0.466 W_p \\ \text{Seismic design force at highest point, } F_{p2} &= 0.495 W_p \end{aligned} \quad F_{p(AVG)} = 0.480$$

$$\text{Min. seismic design force, } F_{p\min} = 0.293 W_p$$

$$\text{Max. seismic design force, } F_{p\max} = 1.563 W_p$$

Seismic design force, F_p (ASD) = 0.343 W_p

 250 4th Ave. South Suite 200 Edmonds, WA 98020	Description	By	CGP	Date	9/16/2020
	Seismic Loads For Components & Systems	Checked		Date	
	Project	Scale	N.T.S.	Sheet No.	10
	SE06033A Burke	Job No.	20070.611		

Wind Load Calculation for Other Structures

(Reference: 2015 IBC Section 1609 & ASCE 7-10 Chapter 29)

Wind Velocity Pressure:

Average Roof Height of Building, h (ft)	=	88	(Per Architectural Drawings)
Height of Other Structure, z (ft)	=	95.25	(Per Architectural Drawings)
Basic Wind Speed, V_{3s} (mph)	=	115	(ASCE Figure 26.5-1)
Exposure Category	=	B	(ASCE Section 26.7.3)
Risk Category	=	IV	(IBC Table 1.5-1)
Velocity Pressure Exposure Coefficient, K_z	=	0.98	(ASCE Section 29.3.1 & Table 29.3-1)
Topographic Factor, K_{zt}	=	1.30	(ASCE Section 26.8.2 & Figure 26.8-1)
Wind Directionality Factor, K_d	=	0.85	(ASCE Section 26.6 & Table 26.6-1)
Velocity Pressure, q_z (psf)	=	$0.00256K_zK_{zt}K_dV^2$	(ASCE Eq. 29.3-1)
	qz =	36.50	psf


Design Wind Load on Other Structures

Gust Effect Factor, G	=	0.85	(ASCE Section 26.9)
Net Force Coefficient, C_f	=	1.4	(ASCE Figure 29.4-1 to 29.5-3)
Projected Area Normal to the Wind, A_r or A_t (ft^2)	=	A_t or A_r	(Projected Wind Area)
Design Lateral Wind Load, F (lbs)	=	$qzGC_fA_f$	(ASCE Eq. 29.5-1)

LRFD	F =	43.4	psf x A_t
ASD	F =	26.1	psf x A_t

K_z or K_h (ASCE Table 29.3-1)

Height Z (ft)	Exposure B	Exposure C	Exposure D
0	0.57	0.85	1.03
15	0.57	0.85	1.03
20	0.62	0.90	1.08
25	0.66	0.94	1.12
30	0.70	0.98	1.16
40	0.76	1.04	1.22
50	0.81	1.09	1.27
60	0.85	1.13	1.31
70	0.89	1.17	1.34
80	0.93	1.21	1.38
90	0.96	1.24	1.40
100	0.99	1.26	1.43
120	1.04	1.31	1.48
140	1.09	1.36	1.52
160	1.13	1.39	1.55
180	1.17	1.43	1.58
200	1.20	1.46	1.61

 Suite 200 Edmonds, WA 98020	Description	By	CGP	Date	9/16/2020
	Wind Loads For Components and Systems	Checked	-	Date	
	Project	Scale	N.T.S.	Sheet No.	11
	SE06033A Burke	Job No.	20070.611		

ANTENNA COMPARISON

Existing (Alpha/Gamma)						
Model	Height (in)	Width (in)	Depth (in)	Weight (LBS)	Area1 (ft^2)	Area2 (ft^2)
TMBXX-6516-R2M	59.9	12	6.5	36.2	4.99	2.70
TMBXX-6516-R2M	59.9	12	6.5	36.2	4.99	2.70
FFHH-65C-R3	95.9	25.2	9.3	127.6	16.78	6.19
AHFIB	22	12.1	5.9	66.1	1.85	0.90
COVP	20.0	16.0	8.0	25	2.22	1.11
AHLOA	22.1	12.2	7.5	83.9	1.87	1.15
FXFB	16.6	17.6	5.2	55.1	0.34	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
Total				474.10	33.72	15.58

Proposed (Alpha/Gamma)						
Model	Height (in)	Width (in)	Depth (in)	Weight (LBS)	Area1 (ft^2)	Area2 (ft^2)
TMBXX-6516-R2M	59.9	12	6.5	36.2	4.99	2.70
AEHC	38.2	21.5	5.9	108	5.70	1.57
FFHH-65C-R3	95.9	25.2	9.3	127.6	16.78	6.19
AHFIG	28.7	12.87	5.59	70.5	2.57	1.12
COVP	20.0	16.0	8.0	25.0	2.22	1.11
AHLOA	22.1	12.2	7.5	83.9	1.87	1.15
FXFB	16.6	17.6	5.2	55.1	2.03	0.27
FRIA	15.6	17.6	5.2	55.1	1.91	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
Total				605.40	38.75	14.93

Existing (Beta)						
Model	Height (in)	Width (in)	Depth (in)	Weight (LBS)	Area1 (ft^2)	Area2 (ft^2)
TMBXX-6516-R2M	59.9	12	6.5	36.2	4.99	2.70
TMBXX-6516-R2M	59.9	12	6.5	36.2	4.99	2.70
FFHH-65C-R3	95.9	25.2	9.3	127.6	16.78	6.19
AHFIB	22	12.1	5.9	66.1	1.85	0.90
COVP	20.0	16.0	8.0	25	2.22	1.11
AHLOA	22.1	12.2	7.5	83.9	1.87	1.15
FXFB	16.6	17.6	5.2	55.1	0.34	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
Total				474.10	33.72	15.58

Proposed (Beta)						
Model	Height (in)	Width (in)	Depth (in)	Weight (LBS)	Area1 (ft^2)	Area2 (ft^2)
TMBXX-6516-R2M	59.9	12	6.5	36.2	4.99	2.70
AEHC	38.2	21.5	5.9	108	5.70	1.57
FFHH-65C-R3	95.9	25.2	9.3	127.6	16.78	6.19
AHFIG	28.7	12.87	5.59	70.5	2.57	1.12
COVP	20.0	16.0	8.0	25.0	2.22	1.11
AHLOA	22.1	12.2	7.5	83.9	1.87	1.15
FXFB	16.6	17.6	5.2	55.1	2.03	0.27
FRIA	15.6	17.6	5.2	55.1	1.91	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
PCS/AWS TMA	6.3	7.7	6.2	22	0.34	0.27
HCS 2.0 Pendant	14.9	9.3	5.8	8.76	0.96	0.60
HCS 2.0 Pendant	14.9	9.3	5.8	8.76	0.96	0.60
Total				622.92	40.67	16.13




250 4th Ave. South
Suite 200
Edmonds, WA 98020

Description	By	CGP	Date	9/16/2020
Antenna Comparison	Checked		Date	
Project	Scale		Sheet No.	
SE06033A Burke WT	Job No.	20070.667		12

SE06033A BURKE

ANTENNA MOUNTS

PIPE MOUNT 1 (AEHC ANT)




$$F_{WANT} = \frac{(5.70 \text{ FT}^2)(26.1 \text{ PSF})}{\text{AEHC}} = \underline{199 \#}$$


$$M_A / M_n / R = 0.099 < 1.0$$

EXISTING 2 1/2" Ø PIPE ADEQUATE

*SEE ENERCALC



PIPE MOUNT 2



$$F_1 = \frac{(4.99 \text{ FT}^2)(26.1 \text{ PSF})}{\text{TMBXX-6S1 6-122M}} / 2 = 66 \#$$

$$F_2 = \frac{(2.57 \text{ FT}^2)(26.1 \text{ PSF})}{\text{AHFIG PRU}} = 67 \#$$

$$M_A / M_n / R = 0.124$$

EXISTING 2 1/2" Ø PIPE ADEQUATE

*SEE ENERCALC



250 4th Ave. South
Suite 200
Edmonds, WA 98020
425.778.8500
www.cgengineering.com

Description

ANTENNA MOUNTS

Project

SE06033A BURKE

By

CGP

Checked

Scale

Job No.

20070.667

Date

9/16/20

Date

Sheet No.

13

Steel Beam

FIG. #: KW-06005155

Load Combination	Span#	Max Stress Ratios			Summary of Moment Values					Summary of Shear Values		
		M	V	0.00	Mmax +	Mmax -	Ma Max	Mmx	Mmx/Omega	Ob	Rm	Va Max
Overall Maximum Deflections	3	Dgn. L = 3.00 ft +D-0.60W+H	0.000	0.012	4.00	2.39	1.00	1.00	0.12	16.91	10.12	
	1	Dgn. L = 1.00 ft Dgn. L = 2.00 ft Dgn. L = 3.00 ft	0.099	0.015	0.24	4.00	2.39	1.67	1.00	0.15	16.91	10.12
	3	+D-0.70E+H	0.000	0.000	0.000	4.00	2.39	1.00	1.00	0.00	16.91	10.12
	1	Dgn. L = 1.00 ft Dgn. L = 2.00 ft Dgn. L = 3.00 ft	0.074	0.011	0.18	4.00	2.39	1.67	1.00	0.11	16.91	10.12
3	+D-0.750L+0.750S+0.450W+H	0.009	0.011	0.18	4.00	2.39	1.00	1.00	0.09	16.91	10.12	
1	Dgn. L = 1.00 ft Dgn. L = 2.00 ft Dgn. L = 3.00 ft	0.074	0.011	0.18	4.00	2.39	1.67	1.00	0.11	16.91	10.12	
3	+D-0.750L+0.750S+0.325E+H	0.000	0.000	0.000	4.00	2.39	1.00	1.00	0.00	16.91	10.12	
1	Dgn. L = 1.00 ft Dgn. L = 2.00 ft Dgn. L = 3.00 ft	0.000	0.000	0.000	4.00	2.39	1.00	1.00	0.00	16.91	10.12	
3	+D-0.60W+0.60H	0.000	0.000	0.000	4.00	2.39	1.00	1.00	0.00	16.91	10.12	
1	Dgn. L = 1.00 ft Dgn. L = 2.00 ft Dgn. L = 3.00 ft	0.012	0.015	0.24	4.00	2.39	1.67	1.00	0.12	16.91	10.12	
3	+D-0.60D+0.70E+0.60H	0.099	0.015	0.24	4.00	2.39	1.00	1.00	0.15	16.91	10.12	
1	Dgn. L = 1.00 ft Dgn. L = 2.00 ft Dgn. L = 3.00 ft	0.000	0.000	0.000	4.00	2.39	1.00	1.00	0.00	16.91	10.12	
3	+D-0.60D+0.70E+0.60H	0.000	0.000	0.000	4.00	2.39	1.00	1.00	0.00	16.91	10.12	

Overall Maximum Deflections

Load Combination	Span	Max. ** Drell	Location in Span	Load Combination	Max. ** Drell	Location in Span
W Only	1	0.0054	0.000		0.0000	0.000
	2	0.0000	0.000	W Only	-0.0042	1.160
W Only	3	0.0542	3.000		0.0000	1.160

Support rotation : Far left is #1
Values in k/PS

Vertical Reactions

Load Combination	Support 1	Support 2	Support 3	Support 4
Overall Maximum	-0.197	0.446		
Overall Minimum	-0.089	0.201		
+D+0.60W+H	-0.118	0.267		
+D+0.750L+0.750L+0.450W+H	-0.089	0.201		
+D+0.750L+0.750S+0.450W+H	-0.089	0.201		
+D+0.750L+0.60W+0.30H	-0.089	0.201		
W Only	-0.197	0.446		
H Only				

Steel Beam


Lic. # : KW-06005155

CODE REFERENCES

Calculations per AISC 360-10, IBC 2012, CBC 2013, ASCE 7-10
Load Combination Set: IBC 2018

Material Properties

Analysis Method:	Allowable Strength Design	Fy: Steel Yield:	35.0 ksi
Beam Bracing:	Completely Unbraced	E: Modulus:	29,000.0 ksi
Bending Axis:	Major Axis Bending		



Applied Loads

Beam self weight NOT internally calculated and added
Load(s) for Span Number 3
Point Load : W = 0.2483 k @ 1.590 ft

DESIGN SUMMARY

Maximum Bending Stress Ratio =	0.099 : 1	Pipe2-1/2STD	0.015 : 1	Pipe2-1/2STD
Section used for this span	Ma : Applied	0.237 k-ft	Section used for this span	Va : Applied
Mn / Omega : Allowable	2.393 k-ft	Vn/Omega : Allowable		
Load Combination			Load Combination	
Location of maximum on span			Location of maximum on span	
Span # where maximum occurs			Span # where maximum occurs	
Maximum Deflection				
Max Downward Transient Deflection	0.064 in	Ratio = 1.121	>=100	
Max Upward Transient Deflection	-0.004 in	Ratio = 5.715	>=100	
Max Downward Total Deflection	0.039 in	Ratio = 1.870	>=100	
Max Upward Total Deflection	-0.003 in	Ratio = 9526	>=100	

Maximum Forces & Stresses for Load Combinations


Load Combination	Span #	Max Stress Ratios			Summary of Moment Values				Summary of Shear Values				
		M	V	Mmax +	Mmax -	Ma Max	Mix	Max/Omega	Ch	Rm	Va Max	Vrx	Vr/Omega
+D-H	1		0.000				4.00	2.39	1.00	1.00	-0.00	16.91	10.12
	2	Dsgn. L = 2.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
	3	Dsgn. L = 3.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
+D-H+H	1		0.000				4.00	2.39	1.00	1.00	-0.00	16.91	10.12
	2	Dsgn. L = 2.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
	3	Dsgn. L = 3.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
+D-L+H	1		0.000				4.00	2.39	1.00	1.00	-0.00	16.91	10.12
	2	Dsgn. L = 2.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
	3	Dsgn. L = 3.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
+D-S-H	1		0.000				4.00	2.39	1.00	1.00	-0.00	16.91	10.12
	2	Dsgn. L = 2.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
	3	Dsgn. L = 3.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
+D+0.750L+0.750+H	1		0.000				4.00	2.39	1.00	1.00	-0.00	16.91	10.12
	2	Dsgn. L = 2.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
	3	Dsgn. L = 3.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
+D+0.750L+0.750S+H	1		0.000				4.00	2.39	1.00	1.00	-0.00	16.91	10.12
	2	Dsgn. L = 2.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12
	3	Dsgn. L = 3.00 ft	0.000			4.00	2.39	1.00	1.00	-0.00	16.91	10.12	10.12

DESCRIPTION: Pipe Mount 2

DESCRIPTION: Pipe Mount 2

Load Combination		Max Stress Ratios		Summary of Moment Values		Summary of Shear Values	
Segment Length	Span #	M	V	Mmax +	Mmax -	Va Max	Vnx VnOmega
+D+0.750L+0.750L+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+0.750L+0.750S+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+0.60W+H	1	0.011	0.011	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.124	0.016	-0.30	0.30	0.18	16.91
Dagn. L = 2.00 ft	3	0.124	0.013	-0.30	0.30	0.13	16.91
+D+0.70E+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+0.750L+0.750L+0.450W+H	1	0.009	0.009	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.093	0.013	-0.22	0.22	0.14	16.91
Dagn. L = 2.00 ft	3	0.093	0.010	-0.22	0.22	0.10	16.91
+D+0.750L+0.750S+0.450W+H	1	0.009	0.009	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.093	0.013	-0.22	0.22	0.14	16.91
Dagn. L = 2.00 ft	3	0.093	0.010	-0.22	0.22	0.10	16.91
+D+0.750L+0.750S+0.5250E+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+0.60W+0.60H	1	0.011	0.011	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.124	0.016	-0.30	0.30	0.18	16.91
Dagn. L = 2.00 ft	3	0.124	0.013	-0.30	0.30	0.13	16.91
+D+0.60W+0.60H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91

Overall Maximum Deflections		Location in Span		Load Combination		Max. +/- Defl		Location in Span	
W Only	W Only	Span	Support	Span	Support	Span	Support	Span	Support
1	2	0.0056	0.0000	1	2	0.0056	0.0000	1	2
3	3	0.0891	3.000	3	3	0.0891	3.000	3	3
Vertical Reactions		Support 1		Support 2		Support 3		Support 4	
Overall Maximum		-0.182		-0.182		0.521		0.521	
Overall Minimum		-0.087		-0.087		0.235		0.235	
+D+0.60W+H		-0.115		-0.115		0.313		0.313	
+D+0.750L+0.750L+0.450W+H		-0.087		-0.087		0.235		0.235	
+D+0.750L+0.750S+0.450W+H		-0.087		-0.087		0.235		0.235	
+D+0.60W+0.60H		-0.115		-0.115		0.313		0.313	
W Only		-0.192		-0.192		0.521		0.521	



Service loads entered. Load Factors will be applied for calculations.

Applied Loads
Beam self weight NOT internally calculated and added
Load(s) for Span Number 2
Point Load: W = 0.1090 k @ 1.0 ft, (TWBXX)
Load(s) for Span Number 3
Point Load: W = 0.1090 k @ 3.0 ft, (TWBXX)
Point Load: W = 0.1110 k @ 1.50 ft, (HFBG)


DESIGN SUMMARY
Maximum Bending Stress Ratio = 0.124: 1
Section used for this span = Pipe 2-1/2STD
Ma: Applied
Mn / Omega: Allowable
Load Combination
Location of maximum on span
Span # where maximum occurs
Span # 2
Maximum Deflection
Max Downward Transient Deflection
Max Upward Transient Deflection
Max Downward Total Deflection
Max Upward Total Deflection
Ratio = 0.090 in
Ratio = -0.005 in
Ratio = 0.054 in
Ratio = -0.005 in
Ratio = 799 >= 100
Ratio = 5,303 >= 100
Ratio = 1832 >= 100
Ratio = 8639 >= 100

Maximum Forces & Stresses for Load Combinations		Max Stress Ratios		Summary of Moment Values		Summary of Shear Values	
Segment Length	Span #	M	V	Mmax +	Mmax -	Va Max	Vnx VnOmega
+D+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+L+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+H+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91
+D+S+H	1	0.000	0.000	4.00	4.00	2.39	1.00 1.00
Dagn. L = 1.00 ft	2	0.000	0.000	2.39	1.00 1.00	-0.00	16.91
Dagn. L = 2.00 ft	3	0.000	0.000	4.00	4.00	-0.00	16.91

SE06033A BURKE

ANTENNA MOUNTS

CROSSARM * ASSUME ALL LOAD INTO TOP CROSSARM



[AEHC] PIPE

$$F_{1DL} = 108\#(DL) + 50\# = 158\#DL$$

$$F_{1WL} = (5.70\text{FT}^2)(43.4\text{PSF}) = 248\#WL$$

(TMA) (FR1A/FXFB)

$$F_{2DL} = (2)22\#DL + (2)55.1\#DL$$

$$F_{2WL} = (2)(0.27\text{FT}^2)(43.4\text{PSF})$$

$$+ (1)(2.03\text{FT}^2)(43.4\text{PSF})$$

(1) SHIELD

$$F_{2WL} = 112\#(WL)$$

[FFHH-6SC-R3] [AH10A]

$$F_{3DL} = 123\# + 83.9\# + 50\# = 257\#$$

$$F_{3WL} = (16.78\text{FT}^2)(43.4\text{PSF}) = 729\#WL$$

[COVP]

$$F_{4DL} = 25\#(DL)$$

$$F_{4WL} = (2.22\text{FT}^2)(43.4\text{PSF}) = 97\#WL$$

[TMBXX] [AHFIG]

$$F_{5DL} = 36.2\# + 70.5\# + 50\# = 156.7\#$$

$$F_{5WL} = [(4.99\text{FT}^2) + (2.57\text{FT}^2)](43.4\text{PSF})$$
$$= 328\#WL$$

EXISTING $3 \times 3 \times \frac{1}{4}$ " ANGLE IS ADEQUATE

* SFE ENERCALL



250 4th Ave. South
Suite 200
Edmonds, WA 98020
425.778.8500
www.cgengineering.com

Description

ANTENNA MOUNTS

Project

SE06033A BURKE

By CAP

Checked

Scale

Job No.

20070.667

Date 9/16/20


Date

Sheet No.

16

SE06033A BURKE

ANTENNA FRAME



$$F_{WIND} = (40.67 \text{ ft}^2)(43.4 \text{ PSF})$$

$$= 1796 \text{ \#/SIDE}$$

$$F_{TOTAL} = (3)(1796 \text{ \#})(0.8)$$

↑
SHIELDING
FACTOR

$$= 4310 \text{ \#(ULT)}; 2586 \text{ \#(ASD)}$$

1/2" Ø THREADED
ROD TIES, TYP


1/2" Ø THREADED ROD BRACES

$$\text{LOAD PER CABLE} = \sqrt{\left(\frac{4310 \text{ \#}}{4}\right)^2 + \left(\frac{4310 \text{ \#}}{4}\right)^2} = 1524 \text{ \#(ULT)}; 914 \text{ \#(ASD)}$$

$$914 \text{ \#} < 1130 \text{ \# CAPACITY (PER ORIGINAL CALCS)}$$

$$T_{R}/T_{RNL} = 0.81 \text{ STRESSED}$$

L3x3x1/4" KICKER



$$F_W = 4310 \text{ \#/2} = 2155 \text{ \#} \quad F_{DL} = 623 \text{ \#}$$

$$F_{KICKER} = \frac{W_L}{\cos 45^\circ} + \frac{D_L}{\cos 45^\circ} = 3929 \text{ \#}$$

EXISTING L3x3x1/4" KICKER
IS ADEQUATE



250 4th Ave. South
Suite 200
Edmonds, WA 98020
425.778.8500
www.cgeengineering.com

Description	By <u>CGP</u>	Date <u>9/16/20</u>
<u>ANTENNA FRAME</u>	Checked	Date
	Scale	Sheet No.
Project	Job No.	
<u>SE06033A BURKE</u>	<u>20070.667</u>	<u>18</u>

Title Block Line 1
You can change this area
using the 'Settings' menu item
and then using the 'Printing &
Title Block' selection.
Title Block Line 6

Title Block Line 1
You can change this area
using the 'Settings' menu item
and then using the 'Printing &
Title Block' selection.
Title Block Line 6

Project Title:
Engineer:
Project ID:
Project Descr:

Project Title:
Engineer:
Project ID:
Project Descr:

Steel Column

Steel Column

LC-71 KW-45003185

LC-71 KW-45003185

DESCRIPTION: Kicker

DESCRIPTION: Kicker

Note: Only non-zero reactions are listed.

Note: Only non-zero reactions are listed.

Maximum Reactions

Maximum Reactions

Load Combination	Axial Reaction @ Base	X-X Axis Reaction @ Base @ Top	Y-Y Axis Reaction @ Base @ Top	Mx - End Moments @ Base @ Top	My - End Moments @ Base @ Top
+D+L+H	0.909				
+D+S+H	0.909				
+D+0.750L+0.750W+H	0.909				
+D+0.750L+0.750S+H	0.909				
+D+0.60W+H	2.738				
+D+0.70E+H	0.909				
+D+0.750L+0.750W+0.450W+H	2.280				
+D+0.750L+0.750S+0.450W+H	2.280				
+D+0.750L+0.750S+0.5250E+H	0.909				
+0.60D+0.60W+0.60H	2.374				
D Only	0.945				
L Only	0.909				
S Only					
W Only					
E Only					
H Only					
	3.048				

Load Combination	Axial Reaction @ Base	X-X Axis Reaction @ Base @ Top	Y-Y Axis Reaction @ Base @ Top	Mx - End Moments @ Base @ Top	My - End Moments @ Base @ Top
+D+L+H	0.909				
+D+S+H	0.909				
+D+0.750L+0.750W+H	0.909				
+D+0.750L+0.750S+H	0.909				
+D+0.60W+H	2.738				
+D+0.70E+H	0.909				
+D+0.750L+0.750W+0.450W+H	2.280				
+D+0.750L+0.750S+0.450W+H	2.280				
+D+0.750L+0.750S+0.5250E+H	0.909				
+0.60D+0.60W+0.60H	2.374				
D Only	0.945				
L Only	0.909				
S Only					
W Only					
E Only					
H Only					
	3.048				

Extreme Reactions

Extreme Reactions

Item	Extreme Value	Axial Reaction @ Base	X-X Axis Reaction @ Base @ Top	Y-Y Axis Reaction @ Base @ Top	Mx - End Moments @ Base @ Top	My - End Moments @ Base @ Top
Axial @ Base	Minimum Maximum	0.909 3.048				
Reaction, X-X Axis Base	Minimum Maximum	0.909 0.909				
Reaction, Y-Y Axis Base	Minimum Maximum	0.909 0.909				
Reaction, X-X Axis Top	Minimum Maximum	0.909 0.909				
Reaction, Y-Y Axis Top	Minimum Maximum	0.909 0.909				
Moment, X-X Axis Base	Minimum Maximum	0.909 0.909				
Moment, Y-Y Axis Base	Minimum Maximum	0.909 0.909				
Moment, X-X Axis Top	Minimum Maximum	0.909 0.909				
Moment, Y-Y Axis Top	Minimum Maximum	0.909 0.909				

Item	Extreme Value	Axial Reaction @ Base	X-X Axis Reaction @ Base @ Top	Y-Y Axis Reaction @ Base @ Top	Mx - End Moments @ Base @ Top	My - End Moments @ Base @ Top
Axial @ Base	Minimum Maximum	0.909 3.048				
Reaction, X-X Axis Base	Minimum Maximum	0.909 0.909				
Reaction, Y-Y Axis Base	Minimum Maximum	0.909 0.909				
Reaction, X-X Axis Top	Minimum Maximum	0.909 0.909				
Reaction, Y-Y Axis Top	Minimum Maximum	0.909 0.909				
Moment, X-X Axis Base	Minimum Maximum	0.909 0.909				
Moment, Y-Y Axis Base	Minimum Maximum	0.909 0.909				
Moment, X-X Axis Top	Minimum Maximum	0.909 0.909				
Moment, Y-Y Axis Top	Minimum Maximum	0.909 0.909				

Maximum Deflections for Load Combinations

Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection	Max. Y-Y Deflection	Distance
+D+H	0.000 in	0.000 in	0.000 ft
+D+L+H	0.000 in	0.000 in	0.000 ft
+D+S+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750W+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750S+H	0.000 in	0.000 in	0.000 ft
+D+0.60W+H	0.000 in	0.000 in	0.000 ft
+D+0.70E+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750W+0.450W+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750S+0.450W+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750S+0.5250E+H	0.000 in	0.000 in	0.000 ft
+0.60D+0.60W+0.60H	0.000 in	0.000 in	0.000 ft
D Only	0.000 in	0.000 in	0.000 ft
L Only	0.000 in	0.000 in	0.000 ft

Load Combination	Max. X-X Deflection	Max. Y-Y Deflection	Distance
+D+H	0.000 in	0.000 in	0.000 ft
+D+L+H	0.000 in	0.000 in	0.000 ft
+D+S+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750W+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750S+H	0.000 in	0.000 in	0.000 ft
+D+0.60W+H	0.000 in	0.000 in	0.000 ft
+D+0.70E+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750W+0.450W+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750S+0.450W+H	0.000 in	0.000 in	0.000 ft
+D+0.750L+0.750S+0.5250E+H	0.000 in	0.000 in	0.000 ft
+0.60D+0.60W+0.60H	0.000 in	0.000 in	0.000 ft
D Only	0.000 in	0.000 in	0.000 ft
L Only	0.000 in	0.000 in	0.000 ft

Code References

Code References

Calculations per AISC 360-10, IBC 2012, CBC 2013, ASCE 7-10
Load Combinations Used : IBC 2018

General Information
Steel Section Name : L3x3x1/4
Analysis Method : Allowable Strength
Steel Stress Grade : 36.0 ksi
Fy: Steel Yield : 29,000.0 ksi
E: Elastic Bending Modulus
Overall Column Height : 5.670 ft
Top & Bottom Fixity : Top & Bottom Pinned
Brace condition for deflection (buckling) along columns :
X-X (width) axis :
Unbraced Length for buckling ABOUT Y-Y Axis = 5.670 ft, K = 1.0
Y-Y (depth) axis :
Unbraced Length for buckling ABOUT X-X Axis = 5.670 ft, K = 1.0
Service loads entered. Load Factors will be applied for calculations.

Applied Loads

Applied Loads

Column self weight included : 27.783 lbs * Dead Load Factor
AXIAL LOADS : ...
Axial Load at 5.670 ft, D = 0.8810, W = 3.048 k

Design Summary

Design Summary

Bending & Shear Check Results
PASS Max. Axial Bending Stress Ratio =
Load Combination :
Location of max. above base :
At maximum location values are :
Px: Axial : 0.0 k
Py: Omega: Allowable : 13.261 k
Max: Applied : 0.0 k-ft
Mix: Omega: Allowable : 1.135 k-ft
Max: Applied : 0.0 k-ft
Mxy: Omega: Allowable : 1.135 k-ft
for load combination :
Along Y-Y : 0.0 in at
for load combination :
Along X-X : 0.0 in at

Load Combination Results

Load Combination Results

Load Combination	Maximum Axial + Bending Stress Ratios	Maximum Shear Ratios	Location
+D+H	0.069 PASS	0.000 PASS	0.00 ft
+D+L+H	0.069 PASS	0.000 PASS	0.00 ft
+D+S+H	0.069 PASS	0.000 PASS	0.00 ft
+D+0.750L+0.750W+H	0.069 PASS	0.000 PASS	0.00 ft
+D+0.750L+0.750S+H	0.069 PASS	0.000 PASS	0.00 ft
+D+0.60W+H	0.206 PASS	0.000 PASS	0.00 ft
+D+0.70E+H	0.069 PASS	0.000 PASS	0.00 ft
+D+0.750L+0.750W+0.450W+H	0.172 PASS	0.000 PASS	0.00 ft
+D+0.750L+0.750S+0.450W+H	0.069 PASS	0.000 PASS	0.00 ft
+D+0.750L+0.750S+0.5250E+H	0.179 PASS	0.000 PASS	0.00 ft
+0.60D+0.60W+0.60H	0.041 PASS	0.000 PASS	0.00 ft

Maximum Reactions
Load Combination :
Axial Reaction : 0.909
@ Base : 0.909
X-X Axis Reaction :
@ Base @ Top :
Y-Y Axis Reaction :
@ Base @ Top :
Mx - End Moments :
@ Base @ Top :
My - End Moments :
@ Base @ Top :
Note: Only non-zero reactions are listed.

Maximum Reactions
Load Combination :
Axial Reaction : 0.909
@ Base : 0.909
X-X Axis Reaction :
@ Base @ Top :
Y-Y Axis Reaction :
@ Base @ Top :
Mx - End Moments :
@ Base @ Top :
My - End Moments :
@ Base @ Top :
Note: Only non-zero reactions are listed.

Title Block Line 1
 You can change this area
 using the 'Settings' menu item
 and then using the 'Printing &
 Title Block' selection.

Printed: 16 SEP 2020, 10:23AM

File: Burke.05

Software copyright ENGRCALC, INC. 1983-2020, build 12.20.1.17

CG ENGINEERING

Steel Column

UC-2: KW-6060515

DESCRIPTION: Kicker


Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection	Distance	Max. Y-Y Deflection	Distance
S Only	0.000 in	0.000 ft	0.000 in	0.000 ft
W Only	0.000 in	0.000 ft	0.000 in	0.000 ft
E Only	0.000 in	0.000 ft	0.000 in	0.000 ft
H Only	0.000 in	0.000 ft	0.000 in	0.000 ft

Steel Section Properties : L3x3x1/4


Depth	=	3.000 in	I xx	=	1.23 in ⁴	J	=	0.031 in ⁴
Leg Width	=	3.000 in	S xx	=	0.57 in ³	Cw	=	0.02 in ⁶
Thickness	=	0.250 in	R xx	=	0.926 in	Ro	=	1.650 in
Area	=	0.250 in ²	Zx	=	1.020 in ³			
Weight	=	4.900 plf	I yy	=	1.230 in ⁴			
Koefgn	=	0.623 in	S yy	=	0.569 in ³			
			R yy	=	0.926 in			
Ycg	=	0.836 in	Qs	=	0.000			
			Iz	=	0.490 in ⁴			
Yp	=	0.240 in	Sz	=	0.415 in ³			
			Rz	=	0.385 in			
Ec	=	0.000 in	TanLz	=	1.00 deg			

Sketches



SEOG033A BURKE

KICKER CONNECTIONS



Check Bolt

* assume $3/4" \varnothing$

$$R_{nv} = \frac{(27 \text{ ksi}) \left(\pi \left(\frac{3/4}{2} \right)^2 \right) (2 \text{ bolts})}{2}$$

$$= 14.28 K > 3.93 K \quad \text{OK}$$

(2) $3/4" \varnothing$ bolts are adequate

Check Weld

* assume 3" long $3/16"$ weld

$$R_n = \frac{0.6 (70 \text{ ksi}) (0.707) (3/16") (3")}{2} = 8.35 K > 2.16 K \quad \text{OK}$$

3" long $3/16"$ fillet weld is adequate

Check Epoxy

* assume 4" x 4" sq plate, minimum

$$\text{Allowable } T = 2790 \text{ psi} (4") (4")$$

$$T = 44.6 K$$

$$>> F = 2.16 K \quad \text{OK}$$

4" x 4" Belzona III is adequate



250 4th Ave. South
Suite 200
Edmonds, WA 98020
425.778.8500
www.cgengineering.com

Description Kicker Connection

Project SEOG033A BURKE

By MBB

Checked

Scale NTS

Job No.

20070.667

Date 9/16/20

Date

Sheet No.

21

PRODUCT SPECIFICATION SHEET

BELZONA 1111

FN10132



ABRASION

Taber

The Taber abrasion resistance determined in accordance with ASTM D4060 with 1 kg load is typically:

H10 Wheels (Wet) 852 mm³ loss per 1000 cycles
CS17 Wheels (Dry) 24 mm³ loss per 1000 cycles

ADHESION

Tensile Shear

When tested in accordance with ASTM D1002, using degreased strips, grit blasted to a 3-4 mil profile, typical values will be:

Mild steel 2,790 psi (19.2 MPa)
Brass 1,650 psi (11.4 MPa)
Copper 2,060 psi (14.2 MPa)
Stainless steel 2,960 psi (20.4 MPa)
Aluminium 1,950 psi (13.4 MPa)

Tensile fatigue

The Tensile fatigue in accordance with ASTM D3166 at ambient temperature and 653 psi (4.5MPa) applied static tensile stress is >1,000,000 cycles.

Pull Off Adhesion

When tested in accordance with ASTM D 4541/ ISO 4624, the pull off strength from grit blasted steel will be typically:

3240 psi (22.3 MPa) 68°F (20°C) cure
2980 psi (20.5 MPa) 212°F (100°C) cure

Cleavage strength

When tested in accordance with ASTM D 1062, the cleavage strength to grit blasted steel will be typically:

1199 pli 68°F (20°C) cure

CHEMICAL ANALYSIS

The mixed Belzona 1111 has been independently analyzed for halogens, heavy metals, and other corrosion-causing impurities, with the following typical results:

Analyte	Total Concentration (ppm)
Fluoride	224
Chloride	398
Bromide	ND (<12)
Sulfur	1019
Nitrite	ND (<6)
Nitrate	4
Zinc	3.4
Antimony, Arsenic, Bismuth, Cadmium, Lead, Tin, Silver, Mercury, Gallium and Indium	ND (<3.0)

ND : Not Detected

CHEMICAL RESISTANCE

Once fully cured, the material will demonstrate excellent resistance to most commonly found inorganic acids and alkalis at concentrations up to 20%.

The material is also resistant to hydro-carbons, mineral oils, lubricating oils and many other commonly found chemicals.

* For a more detailed description of chemical resistance properties, refer to relevant Chemical Resistance chart.

COMPRESSION PROPERTIES

When determined in accordance with ASTM D695 (1.0in/25.4mm thick test pieces), typical values will be:

	Cure temperature
Compressive Strength (Maximum)	
12525 psi (86.4 MPa)	68°F (20°C)
16645 psi (114.8 MPa)	212°F (100°C)

Compressive Strength (Yield)	
9620 psi (66.3 MPa)	68°F (20°C)
10955 psi (75.6 MPa)	212°F (100°C)

Compressive Modulus	
1.77 x 10 ⁵ psi (1217 MPa)	68°F (20°C)
1.75 x 10 ⁵ psi (1205 MPa)	212°F (100°C)

When determined using a modified version of ASTM D695, at thickness more representative of in service application, typical values will be:

Thickness	Compressive Strength (Yield)	Cure Temperature
0.24 in (6.0 mm)	13095 psi (90.3 MPa) 16450 psi (113.4 MPa)	68°F (20°C) 212°F (100°C)
0.12 in (3.0 mm)	14855 psi (102.5 MPa) 18980 psi (130.9 MPa)	68°F (20°C) 212°F (100°C)

Bonded to grit blasted mild steel (single side)

Thickness	Compressive Strength (Yield)	Cure Temperature
0.12 in (3.0 mm)	19910 psi (137.3 MPa) 23840 psi (164.4 MPa)	68°F (20°C) 212°F (100°C)

CORROSION PROTECTION

Corrosion Resistance

Will show no visible signs of corrosion after 5,000 hours exposure in the ASTM B117 salt spray cabinet.

CABINET ANCHORAGE DESIGN

Input Values

B =	31.6 in	(Least out-out dimension of equipment footprint)
L =	30 in	(Equipment Length)
d =	23.27 in	(Distance between anchors/Smallest moment arm)
H =	60.4 in	(Equipment height)
Wt =	2206 lbs	(Equipment weight)
S _{ds} =	0.977	

Applied Forces (LRFD; see previous EQ & Wind calcs)

F_{eh} = Seismic Coefficient * Wt =	1060 lbs
$F_{ev} = \pm 0.2S_{ds}Wt =$	431 lbs
F_{wh} = Horiz Pressure * [(B or L)*H] =	576 lbs
F_{wv} = Vert Pressure * (B*L) =	0 N/A when H>60'

Load Combinations for Max Uplift

	LRFD	ASD
EQ	0.9D + 1.0E	0.6D + 0.7E
Wind	0.9D + 1.0W	0.6D + 0.6W

Overturning Moment

$$\begin{aligned} M_{OTE} &= F_{Eh}H/2 = && 32,001 \text{ in-lbs} \\ M_{OTW} &= F_{Wh}H/2 = && 17,388 \text{ in-lbs} \end{aligned}$$

Resisting Moment

$$M_p = (Wt)d/2 = 25,667 \text{ in-lbs}$$
Max Uplift


LRFD (lbs/side)		ASD (lbs/side)	
$T_E = (1.0M_{OTE} - 0.9M_R)/d + F_{EW}/2 =$	598	$T_E = (0.7M_{OTE} - 0.6M_R)/d + 0.7F_{EW}/2 =$	452
$T_W = (1.0M_{OTW} - 0.9M_R)/d + F_{WW}/2 =$	-245	$T_W = (0.6M_{OTW} - 0.6M_R)/d + 0.6F_{WW}/2 =$	-213

Max Shear

LRFD (lbs/side)		ASD (lbs/side)	
$V_E = 1.0F_E/2 =$	530	$V_E = 0.7F_E/2 =$	371
$V_W = 1.0F_W/2 =$	288	$V_W = 0.6F_W/2 =$	173


Summary of Anchorage Forces

LRFD		
Tension, T =	598	lbs/side
Shear, V =	530	lbs/side
ASD		
Tension, T =	452	lbs/side
Shear, V =	371	lbs/side



Summary of Anchorage

Use (4) 3/8" Hilti Kwik Bolt TZ wedge anchors with 2" embedment into concrete slab, (1) at each corner of the unit, Min.

 250 4th Ave. South Suite 200 Edmonds, WA 98020	Description	Equipment Anchorage	By	CGP	Date	9/18/2020
		HPL3 Battery Cabinet	Checked		Date	
	Project	SE06033A Burke	Scale	N.T.S.	Sheet No.	23
			Job No.	20070.667		



PROJECT INFORMATION:

BURKE
SE06033A

6563 SUNSET AVE NE
BREMERTON, WA 98310

ISSUED FOR:

BUILDING PERMIT

[illegible]

PLANS PREPARED BY: 3

B. J. THOMAS, P.E.
7607 80TH AVE NE
MARYSVILLE, WA 98270
206-851-1106

=DRAWN BY:=====CHK BY:=====

三

2

LICENSURE:



DRAWING INFORMATION:


DO NOT SCALE DRAWINGS. CONTRACTOR MUST VERIFY ALL DIMENSIONS AND ADVISE CONSULTANTS OF ANY ERRORS AND OMISSIONS. ALL PREVIOUS ISSUES OF THIS DRAWING ARE SUPERSEDED BY THE LATEST REVISION. THE INFORMATION CONTAINED IN THIS SET OF DOCUMENTS IS PROPRIETARY BY NATURE. ANY USE OR DISCLOSURE OTHER THAN WHICH IS RELATED TO NAMED CLIENT IS STRICTLY PROHIBITED.

DRAWING TITLE:

OVERALL SITE PLAN

=DRAWING NUMBER: 3

TA



OVERALL SITE PLAN

22x34 SCALE: 1" = 20'

11x17 SCALE: 1" = 40'

