

Review comment responses to Kitsap County Permit #20-03281

1. Environmental Review: A geotech report was prepared for the development of the new CK High School and Middle School, the demolition of the old CK High School, and the Renovation of the 900 Building. The geotech report is attached. The access path stairs are located outside of any landslide concern area.
2. Stormwater Review: There is no trail. It is a short section of stairs allowing access from Dahl Road to Building 900. Both of these properties are owned by Central Kitsap School District. The access path stairs are not located on a Kitsap County Right of Way. See cross section sketch below.

