

Reviewed for Code Compliance
Kitsap County Building/ Fire Marshals
08/12/20203:13:11 PM kwlodarchak

13 steps, 72" wide, 24" deep, with a 7-1/2" rise. Wooden timber construction with gravel infill. Standard safety handrails on both sides. Steps are sloped back to front to avoid ponding.

Permit Number: 20-03201