


Subject To Field Inspection

Remarks



Reviewed for code compliance
with IRC 2015
Kitsap County Building Department
GShapiro@co.kitsap.wa.us
01/13/2021

Validity of permit. The issuance or granting of a permit shall not be construed to be a permit for, or an approval of, any violation of any of the provisions of the International Codes or any other ordinance of Kitsap County. Permits presuming to give authority to violate or cancel the provisions of the International Codes and ordinances of Kitsap County shall not be valid. IBC & IRC 105


Egress window

Peters
20-05588

**CHANGES
MUST Be Approved Prior
To Performing Work**

**Must Comply With
All Washington
State Codes**

Permit Number: 20-05588



Smoke & carbon monoxide detectors required.
Smoke and carbon monoxide detectors must be installed throughout the building in all locations required by the IRC as amended by WAC.

Reviewed for code compliance
with IRC 2015
Kitsap County Building Department
GShapiro@co.kitsap.wa.us
01/13/2021

CHANGES
MUST Be Approved Prior
To Performing Work