

# Simple Heating System Size: Washington State

**CHANGES**  
**MUST Be Approved Prior**  
**To Performing Work**

Reviewed for code compliance  
with IRC 2015  
Kitsap County Building Department  
GShapiro@co.kitsap.wa.us  
06/08/2020

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

## Project Information

Noble Fir  
Silverthorne  
Silverdale, WA 98383

## Contact Information

Scott Delhaute  
360-340-6220  
sdelhaute@AOL.com

## Heating System Type:

☒ All Other Systems

☐ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

## Design Temperature

[Instructions](#)

Bremerton

Design Temperature Difference ( $\Delta T$ )  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

41

## Area of Building

### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

2,680

### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.0

Conditioned Volume  
21,440

## Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 319 = 89.18

U-Factor X Area = UA  
0.50 X 0 = ---

## Skylights

[Instructions](#)

## Insulation

### Attic

[Instructions](#)

R-49

U-Factor X Area = UA  
0.026 X 1,840 = 47.84

### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

No Vaulted Ceilings in this project.

U-Factor X Area = UA  
--- X 0 = ---

### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 3,116 = 174.50

### Floors

[Instructions](#)

R-30

U-Factor X Area = UA  
0.029 X 1,430 = 41.47

### Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA  
0.028 X 0 = ---

### Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA  
0.303 X 0 = ---

### Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA  
--- X 0 = ---

## Location of Ducts


[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient  
1.10

Sum of UA 352.99  
Envelope Heat Load 14,472 Btu / Hour  
Sum of UA X  $\Delta T$   
Air Leakage Heat Load 9,494 Btu / Hour  
Volume X 0.6 X  $\Delta T$  X .018  
Building Design Heat Load 23,966 Btu / Hour  
Air Leakage + Envelope Heat Loss  
Building and Duct Heat Load 26,363 Btu / Hour  
Ducts in unconditioned space: Sum of Building Heat Loss X 1.10  
Ducts in conditioned space: Sum of Building Heat Loss X 1  
Maximum Heat Equipment Output 36,908 Btu / Hour  
Building and Duct Heat Loss X 1.40 for Forced Air Furnace  
Building and Duct Heat Loss X 1.25 for Heat Pump

Figure 1.



Established Basic Permit #  
**19-01655**

Permit Number: 20-02212

(07/01/13)